



Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II ,

SALT LAKE CITY , KOLKATA ,WEST BENGAL, INDIA

Phone : 033-23398220,033-23211690 FAX : 033-23211960

Sub	TENDER CHANGE NOTICE (TCN-01 DTD. 13/04/2018)
Job	"REPLACEMENT OF GEAR BOX OF BOWL MILL # 6D AT UNIT-6, 500 MW, KAHALGAON STPP, NTPC, BIHAR".
Ref	TENDER NO.: PSER:PUR:KGN-S306:18 (ENQ:18:PP:0015:PUR:1) Date 09/04/2018.

1) [With reference to above, following clarifications, relevant to tender, may please be noted and complied with while submitting the offer.](#)

Sl. no.	Description/ Tender clause	As appeared in tender	Bidder's Query	BHEL's reply
1	Sl. No. A Description of Work, sub sl. no. (i) of Annexure-I	Deployment & commissioning of the 120/125 MT or above capacity crawler crane at site to start the work. After commissioning of the crane, vendor has to keep the crane upto completion of the work/as per requirement.	Whether equivalent capacity of tyre mounted crane can be deployed by bidder alternatively after ensuring technical suitability?	Bidder may also deploy tyre mounted crane (120 / 125 MT or above capacity) ensuring technical suitability & site accessibility to handle / erect maximum single item weight of 71MT instead of crawler crane (120 /125 MT or above capacity).

2) 'No deviation certificate' is attached. Bidder to submit their offer along with stamped & signed copy of this TCN & 'No deviation certificate' as per attached format only.

3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DGM (PURCHASE)

(Signature, date & seal of authorized representative of the contractor)

ANNEXURE - IV

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

To,
Bharat Heavy Electricals Limited,
POWER SECTOR – EASTERN REGION
2nd FLOOR, Block-DJ, Plot- 9/1, SECTOR
SALT LAKE CITY, KOLKATA – 700 091
FAX – 033-2321-1960

Job: “REPLACEMENT OF GEAR BOX OF BOWL MILL # 6D AT UNIT-6, 500 MW, KAHALGAON STPP, NTPC, BIHAR”.

E-Tender No.: PSER:PUR:KGN-S306:18 (ENQ:18:PP:0015:PUR:1) Date 09/04/2018 along with TCN-01 dtd. 13/04/2018.

Dear Sir/Madam,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/modified the tender documents as appeared in the website/newspapers and in case of observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT *and confirm our acceptance to **reverse auctioning process*** and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the contractor)