



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 02

Ref: PSER:SCT:RMM-C1858:TCN-02

Date: 01-11-2017

Sub	Tender change notice (TCN) 02	
Job	Design, supply/delivery, storage at site, erection, assembly of removable/re-erectable type pre-engineered, pre-fabricated office building and steel closed storage shed with associated civil works including foundations, modular furniture etc, leveling /grading of the land, road & drain works, security kiosk, fencing & yard lighting of the entire storage yard for 3x40 MW Rammam Stage III Hydroelectric Project, Darjeeling.	
Ref	1.0	Tender no PSER:SCT:RMM-C1858:17
	2.0	BHEL's NIT, vide reference no. PSER:SCT:RMM-C1858:6130 Dated 09-10-2017.
	3.0	BHEL's TCN-01, vide reference PSER:SCT:RMM-C1858:TCN-01, dated 23-10-2017.
	4.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Revised Price Schedule, **VOLUME-III-R-01** attached superseding PRICE SCHEDULE VOLUME-III-R-00 issued earlier along with NIT. Bidder shall quote as per this revised Volume-III, Rev-01 only. Bidders are also requested to submit a declaration in techno - commercial offer that they have submitted their price bid as per **REVISED price schedule** format (**VOLUME-III-PRICE SCHEDULE, REV-01**).
- 2.0 Revised TCC, **VOLUME-IF-TS-1-R1** attached superseding TCC, VOLUME-IF-TS-1-R0 issued earlier along with NIT.
- 3.0 The clarifications to bidders queries are attached at Annexure-A.
- 4.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 5.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HYEAVY ELECTRICALS LTD

SR ENGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

Sl no	Reference clause of tender document	Existing provision	Bidder's query	BHEL's clarification
1	VOL-IF_C1858, Page No. 19/49. 3.d)	Cladding: Liner panel/ Partition	Liner panel/Partition will be placed in all areas or certain area of store	Partition is only for AC Room of the store
2	Page No. 17/49. 2.vi) & Page No. 23/49. Drawing Note No. 15	Clarification on Doors size and type	In specification it is mentioned that Sliding doors size of 4.65mX5m and small one man entry gate size and quantity not mentioned. But in drawing it is mentioned that 4nos. rolling shutter size of 3.5mX3.5m	Sliding door 1 nos 4.65m x5m in each gable end. Hence, total 2 nos. will be required.
3	Page No. 23/49. Drawing Note No. 14		Cement store height is 3.5m mentioned in the drawing. What is it for?	Please ignore. Not applicable for this tender.
4	Page No. 34/49. 2.5.1. & 4 & Page No. 40/49. Drawing Note	Specification For Door & Windows are mismatch from Drawing	In Specification for Door on page no. 34. Outer Door FRP and Window Aluminium. In page no. 36. Internal Door Polymeric, External solid core PVC/ wooden and aluminium window. In Page no. 40. Outer door solid core particle, Inner door Aluminium and Toilet PVC door. And Steel windows.	Outer door :Solid core flush door Inner Door(except Toile):- Glass with Solid core flush door Toilet: 25mm thick PVC door
5	Page No. 38/49. Sl. No. 14	Networking	Details Specification not mentioned	Networking for LAN connection for 20(twenty) user
6	Page No. 37/49. Sl. No. 12	Modular Furnishing	Point No. x & xi Cot size not mentioned. xii) Refrigerator make not mentioned iii) Cubical and Part Cabin Location iv) Push pull type Cabinet Location Table for HOD required or not	*Cot size shall be Indian traditional size * Refrigerator shall be Samsung/LG/Videocon or equivalent * Cabinet:-3 Nos. (4 rack each of the cabinet) size of the cabinet approx. 500(w)x600(D)x1500(H)
7	Page No. 37/49. Sl. No. 9	Air Conditioning	AC quantity required	13 nos. Split AC of having 1.5 T capacity for office
8	Page No. 37/49. Sl. No. 8	Electrical Works	Quantity Required	As per requirement

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
 Power Sector - Eastern Region,
 Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, supply/delivery, storage at site, erection, assembly of removable/re-erectable type pre-engineered, pre-fabricated office building and steel closed storage shed with associated civil works including foundations, modular furniture etc, leveling /grading of the land, road & drain works, security kiosk, fencing & yard lighting of the entire storage yard for 3x40 MW Rammam Stage III Hydroelectric Project, Darjeeling.	
Ref	1.0	Tender no PSER:SCT:RMM-C1858:17
	2.0	BHEL's NIT, vide reference no. PSER:SCT:RMM-C1858:6130 Dated 09-10-2017.
	3.0	BHEL's TCN-01, vide reference PSER:SCT:RMM-C1858:TCN-01, dated 23-10-2017.
	4.0	BHEL's TCN-02, vide reference PSER:SCT:RMM-C1858:TCN-02, dated 01-11-2017.
	5.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796