



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 03

Ref: PSER:SCT:KLN-B1871:TCN-03

Date: 17-02-2018

Sub	Tender change notice (TCN) 03	
Job	PACKAGE-A: Erection, testing, commissioning, etc of Boiler & Auxiliaries of 1x660 MW unit # 1 including Auxiliary Boiler, O&M of cranes and providing FSA engineers for 2x660 MW Maitree STPP, Rampal, Bangladesh.	
Ref	1.0	Tender no PSER:SCT:KLN-B1871:18
	2.0	BHEL's NIT, vide reference no PSER:SCT:KLN-B1871:6436, Date: 23-01-2018.
	3.0	BHEL's TCN-01 vide ref : PSER:SCT:KLN-B1871:TCN-01 dated 12-02-2018
	4.0	BHEL's TCN-02 vide ref : PSER:SCT:KLN-B1871:TCN-02 dated 12-02-2018
	5.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Reply to Bidder's query is attached as per **Annexure-A to TCN-03**.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY.MGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	PACKAGE-A: Erection, testing, commissioning, etc of Boiler & Auxiliaries of 1x660 MW unit # 1 including Auxiliary Boiler, O&M of cranes and providing FSA engineers for 2x660 MW Maitree STPP, Rampal, Bangladesh.	
Ref	1.0	Tender no PSER:SCT:KLN-B1871:18
	2.0	BHEL's NIT, vide reference no PSER:SCT:KLN-B1871:6436, Date: 23-01-2018.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:KLN-B1871:TCN-01, Dated 08-02-2018.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:KLN-B1871:TCN-02, Dated 12-02-2018.
	5.0	BHEL's TCN-03,vide reference no PSER:SCT:KLN-B1871:TCN-03 dated 17-02-2018
	6.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

ANNEXURE-A TO TCN - 03

SL No	REFERENCE CLAUSE OF TENDER DOC	EXISTING PROVISION	BIDDER QUERY	BHEL's REPLY
1	VOL-II-REV00-Technical Specification and Special Conditions of Contract, CI No 5.1, Pg 4 of 13	The agency shall deploy a team of qualified HSE professionals a.1 Sr HSE Officer :40 Months b.1 No HSE Officer 36 months c.1 No HSE Officer - 42 Months d.1 No HSE Officer- 48	The Total Completion time Schedule for the Project is only 31 months (Vol-1F-CML-PKG-A-R0-Technical Conditions of Contract, Pg 29 of 54)	Bidder may refer clause no. 9.0 of "5.2-SCT-KLN-B1871-VOL-IF-CML-FSA-3-R-0" of tender document.
2	VOL-1F-CML-PKG-A-R0-TCC, PG 51 OF 54, Annexure-III, Major Tools And Plants And MMRs To Be Deployed By Successful Bidder	a) SI No 2.0-Hydraulic Crawler Crane-150T or above-1 No -Within 30 days of LOI. b) SI No 3 -Hydraulic Crawler Crane-100T or above -3 Nos 1 st within 15 days of LOI 2 ND within 45 days of LOI 3 rd as per requirement	Total Time Period of Deployment of Cranes is not specified. Also general cranes are deployed post receipt of foundation and other clearance whereas in tender it is shown as deployment within 30 days of LOI, we request to revise the same.	Annex-III (Major Tools And Plants And MMRs To Be Deployed By Successful Bidder) – Required T&P from SI. no. 2 to 8 shall be deployed within the specified duration from date of Start of Work. Further, 'note 2.0' shall be applicable regarding actual requirement and release of T&P at site.
3	VOL-1F-CML-PKG-A-R0-TCC, PG 34 OF 54, CI :44, Terms of Payment	44.2 Progressive Payment shall be made by successful bidder's RA bill, complete and correct in all respects, accompanied by BHEL engineer's certified measurement sheet..... within 60 days of submission of bill	In comparison to other projects, the progress payment is done within 30 days of payment of bill, we request you to revise the same.	As per Tender
4	Vol-1F-TS-R0-Technical Conditions of Contract-SI no 4.0 Pg 13 of 32		PI provide the details of ESP Like No of Pass per Unit of ESP and No of Field per pass	ESP per Unit has four passes and each pass has seven fields

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796