



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 03

Ref: PSER:SCT:KLN-M1862:TCN-03

Date: 24-11-2017

Sub	Tender change notice (TCN) 03	
Job	Design, Engineering, Manufacturing, Supply, Erection & Commissioning, etc of complete IDCT Pkg for 2x660 MW Maitree Super Thermal Power Project, Rampal, Bangladesh.	
Ref	1.0	Tender no PSER:SCT:KLN-M1862:17
	2.0	BHEL's NIT, vide reference no PSER:SCT:KLN-M1862:6223 Dated 27-10-2017
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:KLN-M1862:TCN-01, Dated 16-11-2017.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:KLN-M1862:TCN-02, Dated 22-11-2017.
	5.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarification to bidder's query as per attached Annexure-A.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY.MGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, Engineering, Manufacturing, Supply, Erection & Commissioning, etc of complete IDCT Pkg for 2x660 MW Maitree Super Thermal Power Project, Rampal, Bangladesh.	
Ref	1.0	Tender no PSER:SCT:KLN-M1862:17
	2.0	BHEL's NIT, vide reference no PSER:SCT:KLN-M1862:6223 Dated 27-10-2017
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:KLN-M1862:TCN-01, Dated 16-11-2017.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:KLN-M1862:TCN-02, Dated 22-11-2017.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:KLN-M1862:TCN-03, Dated 24-11-2017.
	6.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

ANNEXURE-A TO TCN-03**Design, Engineering, Manufacturing, Supply, Erection & Commissioning, etc of complete IDCT Pkg for 2x660 MW Maitree Super Thermal Power Project, Rampal, Bangladesh.****Tender no PSER:SCT:KLN-M1862:17**

S.No.	Reference	Subject	Query	BHEL's Clarification
1	Data sheet A page 1 Of 4 Tech spec PE-TS-421-165- N001	Clarified sea water	Please confirm the circulating water quality indicating TSS,TDS, Chloride ph, COC etc	Please refer annexures to the datasheet A of specification for water quality. Cycle of concentration to be considered as 2.0 in case of worst quality of water in dry season.
2	Section 1, Sub section 1 A page 1 of 11	Complete Erection/ Installation of Mechanical/ Electrical/C&I equipment's at Site.	Since we can undertake the supervision of erection only, site storage and material downloading shall be excluded from our cope. Please confirm	Deviation not acceptable. Bidder to follow specification.