



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 15

Ref: PSER:SCT:KLN-M1862:TCN-15

Date:12-01-2018

Sub	Tender change notice (TCN) 15
Job	Design, Engineering, Manufacturing, Supply, Erection & Commissioning, etc of complete IDCT Pkg for 2x660 MW Maitree Super Thermal Power Project, Rampal, Bangladesh.
Ref	1.0 Tender no PSER:SCT:KLN-M1862:17
	2.0 BHEL's NIT, vide reference no PSER:SCT:KLN-M1862:6223 Dated 27-10-2017
	3.0 BHEL's TCN-01, vide reference no PSER:SCT:KLN-M1862:TCN-01, Dated 16-11-2017.
	4.0 BHEL's TCN-02, vide reference no PSER:SCT:KLN-M1862:TCN-02, Dated 22-11-2017.
	5.0 BHEL's TCN-03, vide reference no PSER:SCT:KLN-M1862:TCN-03, Dated 24-11-2017.
	6.0 BHEL's TCN-04, vide reference no PSER:SCT:KLN-M1862:TCN-04, Dated 29-11-2017.
	7.0 BHEL's TCN-05, vide reference no PSER:SCT:KLN-M1862:TCN-05, Dated 02-12-2017.
	8.0 BHEL's TCN-06, vide reference no PSER:SCT:KLN-M1862:TCN-06, Dated 04-12-2017.
	9.0 BHEL's TCN-07, vide reference no PSER:SCT:KLN-M1862:TCN-07, Dated 12-12-2017.
	10.0 BHEL's TCN-08, vide reference no PSER:SCT:KLN-M1862:TCN-08, Dated 16-12-2017.
	11.0 BHEL's TCN-09, vide reference no PSER:SCT:KLN-M1862:TCN-09, Dated 19-12-2017.
	12.0 BHEL's TCN-10, vide reference no PSER:SCT:KLN-M1862:TCN-10, Dated 27-12-2017.
	13.0 BHEL's TCN-11, vide reference no PSER:SCT:KLN-M1862:TCN-11, Dated 01-01-2018.
	14.0 BHEL's TCN-12, vide reference no PSER:SCT:KLN-M1862:TCN-12, Dated 02-01-2018.
	15.0 BHEL's TCN-13, vide reference no PSER:SCT:KLN-M1862:TCN-13, Dated 05-01-2018.
	16.0 BHEL's TCN-14, vide reference no PSER:SCT:KLN-M1862:TCN-14, Dated 12-01-2018.
	17.0 All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Extension of due date of submission of offer from 15-01-2018 to 22-01-2018 (15:00 hrs).
- 2.0 Clarification of bidder's query as per Annexure-A.
- 3.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 4.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY MGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211691, 23398000

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, Engineering, Manufacturing, Supply, Erection & Commissioning, etc of complete IDCT Pkg for 2x660 MW Maitree Super Thermal Power Project, Rampal, Bangladesh.	
Ref	1.0	Tender no PSER:SCT:KLN-M1862:17
	2.0	BHEL's NIT, vide reference no PSER:SCT:KLN-M1862:6223 Dated 27-10-2017
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:KLN-M1862:TCN-01, Dated 16-11-2017.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:KLN-M1862:TCN-02, Dated 22-11-2017.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:KLN-M1862:TCN-03, Dated 24-11-2017.
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:KLN-M1862:TCN-04, Dated 29-11-2017.
	7.0	BHEL's TCN-05, vide reference no PSER:SCT:KLN-M1862:TCN-05, Dated 02-12-2017.
	8.0	BHEL's TCN-06, vide reference no PSER:SCT:KLN-M1862:TCN-06, Dated 04-12-2017.
	9.0	BHEL's TCN-07, vide reference no PSER:SCT:KLN-M1862:TCN-07, Dated 12-12-2017.
	10.0	BHEL's TCN-08, vide reference no PSER:SCT:KLN-M1862:TCN-08, Dated 16-12-2017.
	11.0	BHEL's TCN-09, vide reference no PSER:SCT:KLN-M1862:TCN-09, Dated 19-12-2017.
	12.0	BHEL's TCN-10, vide reference no PSER:SCT:KLN-M1862:TCN-10, Dated 27-12-2017.
	13.0	BHEL's TCN-11, vide reference no PSER:SCT:KLN-M1862:TCN-11, Dated 01-01-2018.
	14.0	BHEL's TCN-12, vide reference no PSER:SCT:KLN-M1862:TCN-12, Dated 02-01-2018.
	15.0	BHEL's TCN-13, vide reference no PSER:SCT:KLN-M1862:TCN-13, Dated 05-01-2018.
	16.0	BHEL's TCN-14, vide reference no PSER:SCT:KLN-M1862:TCN-14, Dated 12-01-2018.
	17.0	BHEL's TCN-15, vide reference no PSER:SCT:KLN-M1862:TCN-15, Dated 12-01-2018.
	18.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALLAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339-8231

ANNEXURE-A TO TCN-15**Design, Engineering, Manufacturing, Supply, Erection & Commissioning, etc of complete IDCT Pkg for 2x660 MW Maitree Super Thermal Power Project, Rampal, Bangladesh.****Tender no PSER:SCT:KLN-M1862:17**

S.No.	Reference	Description	Query	Clarification
1	TCN 13 dated. 05.01.2018	Soil investigation report	<p>We refer your TCN 13 received. Soil investigation report indicates & highlights following : Pre cast driven piles 1. 400 mm 2. 800 mm Cast in situ 1. 600 mm 2. 900 mm</p> <p>Kindly let us know which one to be considered ? Are we suppose to design for all requirement ? If yes, we request you to provide unit rate to be considered in Price schedule (VOL-III A_Price Schedule (Absolute value) – Rev-00 / pg. 13 of 14) for all.</p>	Civil specification stipulates the pile size i.e. 350 mm square driven piles and vendors to consider 350mm square pile only.
2	TCN 13 dated. 05.01.2018	Soil investigation report	<p>On detailed study of the new soil report, we wish to inform you that based on the specified pile capacities, adopting 400 mm square driven pre-cast piles instead of 350 mm square driven piles (specified earlier) will result in a much economical cooling tower foundation design.</p> <p>We, therefore, request you to allow cooling tower contractors to consider 400 mm square driven piles in their design.</p> <p>In case above is acceptable to you, we also request you to suitably modify SI No 3.0 and Note No 5.0 in SCH-9 of Price Schedule by incorporating “400 mm square driven pre cast reinforced cement concrete vertical pile” instead of 350 mm square pile.</p>	Civil specification stipulates the pile size i.e. 350 mm square driven piles and vendors to consider all details as per specification only.